



THE UNIVERSITY OF TEXAS AT ARLINGTON

Market Variability Trends Among Copper Grounding Products

Lora Aboulmouna

Jeff Jordan, PE

Copperweld

Is there variability in the copper market?

If so, what does that mean for performance versus the expected standard?



What is the Problem?

- CDEGS published a paper by Jeffrey Jordan, PE
SHORT CIRCUIT (ISC) PERFORMANCE CONSIDERATIONS FOR CCS
- Copperweld 19 No 9 (4/0 copper equivalent)

Conductor	Shot #	Sample #	Voltage	Current	Duration	Comment
			(kV)	(kA)	(ms)	
CCS 19 No. 9	1-1	1	3.9	33.5	508	No fusing
CCS 19 No. 9	2-1	1	4.2	36.2	508	No fusing
CCS 19 No. 9	3-1	2	4.1	53.8	225	Fuse at lug
CCS 19 No. 9	4-1	3	3.8	47.2	258	No fusing




Assessment Overview

- 5 Manufacturers:
CME, Nehring, Southwire, Republic, Cerro and Encore
- 42 total Samples:
4/0, 2/0, #4, #6 wire
- Standards Referenced:
IEEE Standard 80 (substation grounding and short-circuit rating)
ASTM B-3 (Soft or Annealed Copper Wire)
ASTM B-8 (Concentric-Lay Stranded Copper)
ASTM B-787 (19 Wire Combination Unilay-Stranded)



Testing & Measurement Overview



1. **Sample** – cut at approximately 2 ft lengths
2. **Wire diameter** – measured by a laser micrometer
3. **Resistance** – measured using a resistance bridge
4. **Break load** – measured by taking the sum of the individual strands



Application: 4/0 Substation Grounding

Sample #	Brand	Strands	Overall Diameter (in)	Total Area (in ²)	Cross-sectional Area (kcmil)	Total Break Load (lb)	IEEE Short Circuit (KA)	IEEE table 6	max variability
4/0									
1	A	19	0.499	0.159	203.0	6304	41.02	44 kA	8%
8	A	19	0.506	0.165	210.4	6317	42.50		
21	A	19	0.499	0.164	208.9	6226	42.20		
23	B	19	0.497	0.157	199.9	5956	40.38		
26	B	19	0.493	0.157	200.4	6077	40.49		
24	B	7	0.511	0.164	208.3	6041	42.09		
26	C	7	0.518	0.167	212.2	9566	42.87		
22	C	7	0.499	0.166	211.9	9105	42.81		
20	D	19	0.502	0.160	203.4	6095	41.08		

Standard IEEE 80 simplified formula:

$$A_{kcmil} = I * k_f * \sqrt{t_c}$$



Table 1 98%

ASTM B-787	4/0	211.6	207.4	kcmil
& ASTM B-8	2/0	133.1	130.4	kcmil

Sample #	Brand	Strands	Overall Diameter (in)	Total Area (in ²)	Cross-sectional Area (kcmil)	Total Break Load (lb)	IEEE Short Circuit (KA)
4/0							
1	A	19	0.499	0.159	203.0	6304	41.02
8	A	19	0.506	0.165	210.4	6317	42.50
21	A	19	0.499	0.164	208.9	6226	42.20
23	B	19	0.497	0.157	199.9	5956	40.38
26	B	19	0.493	0.157	200.4	6077	40.49
24	B	7	0.511	0.164	208.3	6041	42.09
26	C	7	0.518	0.167	212.2	9566	42.87
22	C	7	0.499	0.166	211.9	9105	42.81
20	D	19	0.502	0.160	203.4	6095	41.08

IEEE table 6	max variability
--------------	-----------------

44 kA 8%

Standard ASTM B-787:

12.1 The cross-sectional area of the completed conductor shall be *not less than 98 %* of the area indicated in Column 1 of Table 1.

Standard ASTM B-8-11:

11.1 The area of cross section of the completed conductor shall be *not less than 98 %* of the area indicated in Column 1 of Table 1.



Application: 2/0 Substation Grounding

Sample #	Brand	Strands	Overall Diameter (in)	Total Area (in ²)	Cross-sectional Area (kcmil)	Total Break Load (lb)	IEEE Short Circuit (KA)	IEEE table 6	max variability
2/0									
2	A	19	0.391	0.102	129.4	3948	26.15	28 kA	8%
9	A	18	0.395	0.103	130.7	3860	26.40		
15	A	19	0.395	0.104	132.7	3950	26.81		
14	B	18	0.393	0.097	124.1	3691	25.06		
16	B	19	0.392	0.100	127.6	3794	25.77		
17	B	7	0.385	0.102	130.2	3807	26.31		
18	B	19	0.398	0.103	130.8	3919	26.43		
19	C	19	0.412	0.103	130.8	3883	26.43		

Standard IEEE 80 simplified formula:

$$A_{kcmil} = I * k_f * \sqrt{t_c}$$



Table 1 98%

ASTM B-787	4/0	211.6	207.4	kcmil
& ASTM B-8	2/0	133.1	130.4	kcmil

Sample #	Brand	Strands	Overall Diameter (in)	Total Area (in ²)	Cross-sectional Area (kcmil)	Total Break Load (lb)	IEEE Short Circuit (KA)
2/0							
2	A	19	0.391	0.102	129.4	3948	26.15
9	A	18	0.395	0.103	130.7	3860	26.40
15	A	19	0.395	0.104	132.7	3950	26.81
14	B	18	0.393	0.097	124.1	3691	25.06
16	B	19	0.392	0.100	127.6	3794	25.77
17	B	7	0.385	0.102	130.2	3807	26.31
18	B	19	0.398	0.103	130.8	3919	26.43
19	C	19	0.412	0.103	130.8	3883	26.43

IEEE table 6	max variability
--------------	-----------------

28 kA 8%

Standard ASTM B-787:

12.1 The cross-sectional area of the completed conductor shall be *not less than 98 %* of the area indicated in Column 1 of Table 1.

Standard ASTM B-8-11:

11.1 The area of cross section of the completed conductor shall be *not less than 98 %* of the area indicated in Column 1 of Table 1.



Preliminary Findings

- 40% of the samples tested out of spec
 - 2 wire samples met the upper limit
 - the remaining 50% met the lower limit of ASTM
- **None** met the ultimate short circuit rating in IEEE standard 80 table 6
 - 4/0 had 3-8% variability range
 - 2/0 had 4-8% variability range



Application: #4 Pole Grounding

Sample #	Brand	Strands	Overall Diameter (in)	Total Area (in ²)	Cross-sectional Area (kcmil)	Total Break Load (lb)	IEEE Short Circuit (KA)	IEEE table 6	max variability
#4									
3	A	7	0.226	0.034	43.2	1324	8.74	9	9%
11	A	7	0.221	0.033	42.5	1275	8.59		
6	A	1	0.206	0.033	42.5	1150	8.58		
10	A	1	0.204	0.033	41.5	1151	8.38		
28	A	1	0.203	0.032	41.2	1149	8.32		
29	B	1	0.201	0.032	40.6	1114	8.19		
32	B	1	0.201	0.032	40.5	1119	8.18		
30	B	7	0.223	0.032	41.0	1207	8.28		
33	B	7	0.220	0.032	41.3	1181	8.35		
0	E	7	0.221	0.032	40.6	1210	8.20		
31	E	1	0.203	0.032	41.3	1159	8.35		
34	C	1	0.205	0.033	41.9	1099	8.46		
27	D	1	0.204	0.033	41.4	1189	8.37		

Standard IEEE 80 :

$$A_{kcmil} = I * k_f * \sqrt{t_c}$$



Sample #	Brand	Strands	Overall Diameter (in)	Total Area (in ²)	Cross-sectional Area (kcmil)	Total Break Load (lb)	IEEE Short Circuit (KA)
#4							
3	A	7	0.226	0.034	43.2	1324	8.74
11	A	7	0.221	0.033	42.5	1275	8.59
6	A	1	0.206	0.033	42.5	1150	8.58
10	A	1	0.204	0.033	41.5	1151	8.38
28	A	1	0.203	0.032	41.2	1149	8.32
29	B	1	0.201	0.032	40.6	1114	8.19
32	B	1	0.201	0.032	40.5	1119	8.18
30	B	7	0.223	0.032	41.0	1207	8.28
33	B	7	0.220	0.032	41.3	1181	8.35
0	E	7	0.221	0.032	40.6	1210	8.20
31	E	1	0.203	0.032	41.3	1159	8.35
34	C	1	0.205	0.033	41.9	1099	8.46
27	D	1	0.204	0.033	41.4	1189	8.37

IEEE table 6	max variability
9	9%

		Table 1	98%	
ASTM B-787 & ASTM B-8	#4	41.74	40.91	kcmil
	#6	26.24	25.72	kcmil

ASTM B-3	#4	0.2023 in
	#6	0.16039 in

Standard ASTM B-3:

5.3 And for diameters of 0.100 in (.254 mm) and over the wire shall not vary from the specified diameter by more than +/- 1%, expressed to the nearest 0.0001 in (or 0.001 mm).

Standard ASTM B-8:

11.1 ... not less than 98 % of the area indicated in Column 1 of Table 1.



Application: #6 Pole Grounding

Sample #	Brand	Strands	Overall Diameter (in)	Total Area (in ²)	Cross-sectional Area (kcmil)	Total Break Load (lb)	IEEE Short Circuit (KA)
#6							
7	A	1	0.162	0.021	26.2	748	5.29
12	A	1	0.164	0.021	26.8	766	5.41
35	A	1	0.162	0.021	26.2	739	5.29
36	A	1	0.161	0.020	25.8	752	5.21
5	A	7	0.181	0.021	26.2	768	5.29
13	A	7	0.180	0.021	26.4	765	5.33
40	B	7	0.220	0.021	26.1	785	5.27
37	B	1	0.160	0.020	25.7	738	5.20
39	B	1	0.161	0.020	25.9	733	5.22
41	C	1	0.162	0.021	26.2	701	5.30
36	E	1	0.161	0.020	26.0	815	5.26
red	F	1	0.164	0.021	26.7	761	5.40

IEEE table 6	max variability
6	13%

Standard IEEE 80 :

$$A_{kcmil} = I * k_f * \sqrt{t_c}$$



Sample #	Brand	Strands	Overall Diameter (in)	Total Area (in ²)	Cross-sectional Area (kcmil)	Total Break Load (lb)	IEEE Short Circuit (KA)
#6							
7	A	1	0.162	0.021	26.2	748	5.29
12	A	1	0.164	0.021	26.8	766	5.41
35	A	1	0.162	0.021	26.2	739	5.29
36	A	1	0.161	0.020	25.8	752	5.21
5	A	7	0.181	0.021	26.2	768	5.29
13	A	7	0.180	0.021	26.4	765	5.33
40	B	7	0.220	0.021	26.1	785	5.27
37	B	1	0.160	0.020	25.7	738	5.20
39	B	1	0.161	0.020	25.9	733	5.22
41	C	1	0.162	0.021	26.2	701	5.30
36	E	1	0.161	0.020	26.0	815	5.26
red	F	1	0.164	0.021	26.7	761	5.40

IEEE table 6	max variability
--------------	-----------------

6	13%
---	-----

		Table 1	98%	
ASTM B-787 & ASTM B-8	#4	41.74	40.91	kcmil
	#6	26.24	25.72	kcmil

ASTM B-3		
	#4	0.2023 in
	#6	0.16039 in

Standard ASTM B-3:

5.3 And for diameters of 0.100 in (.254 mm) and over the wire shall not vary from the specified diameter by more than +/- 1%, expressed to the nearest 0.0001 in (or 0.001 mm).

Standard ASTM B-8:

11.1 ... *not less than 98 %* of the area indicated in Column 1 of Table 1.




Preliminary Findings


- 10% of the samples tested out of spec
 - 70% met or exceeded the upper limit
- **None** met the ultimate short circuit rating in IEEE Standard 80 Table 6
 - #4 had 3-9% variability range
 - #6 had 10-13% variability range



Normal Distribution Model




4/0 Distribution Model




Data


4/0




2/0



#4



#6



Key Take-Aways

- Variability in the market exists

Variability of up to 13% from IEEE short circuit standard
Approximately 25% of samples did not meet ASTM

- Further studies necessary

Larger sample size
Experimental replicates



Questions?

- Contact Info:

- Lora Aboulmouna

- laboulmouna@copperweld.com

- (P): 615-377-4172

- (M): 615-270-5990

- Jeff Jordan

- jjordan@copperweld.com

